

Institutional Tuberculosis Transmission

Controlled Trial of Upper Room Ultraviolet Air Disinfection: A Basis for New Dosing Guidelines

Matsie Mphaphlele¹, Ashwin S. Dharmadhikari², Paul A. Jensen³, Stephen N. Rudnick⁴, Tobias H. van Reenen⁵, Marcello A. Pagano⁶, Wilhelm Leuschner⁷, Tim A. Sears⁸, Sonya P. Milonova⁴, Martie van der Walt⁹, Anton C. Stoltz¹⁰, Karin Weyer¹¹, and Edward A. Nardell^{2,12}

¹MDR-TB Program, JHPIEGO, Pretoria, South Africa; ²Division of Pulmonary and Critical Care Medicine and ¹²Division of Global Health Equity, Department of Medicine, Brigham and Women's Hospital, Boston, Massachusetts; ³CDC Division of Tuberculosis Elimination, National Center for HIV/AIDS, Viral Hepatitis, STD, and TB Prevention, Atlanta, Georgia; ⁴Department of Environmental Health, Harvard School of Public Health, Boston, Massachusetts; ⁵Council for Scientific and Industrial Research, Pretoria, South Africa; ⁶Harvard School of Public Health, Boston, Massachusetts; ⁷Department of Electronic and Computer Engineering, University of Pretoria, Pretoria, South Africa; ⁸Acuity Brands Lighting, Connors, Georgia; ⁹Medical Research Council, Pretoria, South Africa; ¹⁰Division of Infectious Diseases, Internal Medicine, University of Pretoria Medical School, Pretoria, South Africa; and ¹¹Global Tuberculosis Programme, World Health Organization, Geneva, Switzerland

ORCID ID: 0000-0002-5323-3196 (E.A.N.).

Abstract

Rationale: Transmission is driving the global tuberculosis epidemic, especially in congregate settings. Worldwide, natural ventilation is the most common means of air disinfection, but it is inherently unreliable and of limited use in cold climates. Upper room germicidal ultraviolet (UV) air disinfection with air mixing has been shown to be highly effective, but improved evidence-based dosing guidelines are needed.

Objectives: To test the efficacy of upper room germicidal air disinfection with air mixing to reduce tuberculosis transmission under real hospital conditions, and to define the application parameters responsible as a basis for proposed new dosing guidelines.

Methods: Over an exposure period of 7 months, 90 guinea pigs breathed only untreated exhaust ward air, and another 90 guinea pigs breathed only air from the same six-bed tuberculosis ward on

alternate days when upper room germicidal air disinfection was turned on throughout the ward.

Measurements and Main Results: The tuberculin skin test conversion rates (>6 mm) of the two chambers were compared. The hazard ratio for guinea pigs in the control chamber converting their skin test to positive was 4.9 (95% confidence interval, 2.8–8.6), with an efficacy of approximately 80%.

Conclusions: Upper room germicidal UV air disinfection with air mixing was highly effective in reducing tuberculosis transmission under hospital conditions. These data support using either a total fixture output (rather than electrical or UV lamp wattage) of 15–20 mW/m³ total room volume, or an average whole-room UV irradiance (fluence rate) of 5–7 μW/cm², calculated by a lighting computer-assisted design program modified for UV use.

Keywords: tuberculosis transmission; infection control; air disinfection; ultraviolet irradiation; tuberculosis prevention

Supported by CDC/National Institute for Occupational Safety and Health grant 1R01 OH009050 and National Institutes of Health/Fogarty International grant 1D43TW009379.

Author Contributions: Conception and design, M.M., A.S.D., P.A.J., K.W., and E.A.N. Study management, M.M., A.S.D., P.A.J., M.v.d.W., K.W., and E.A.N. Provision of key expertise and measurements, P.A.J., S.N.R., T.H.v.R., W.L., T.A.S., S.P.M., A.C.S., K.W., and E.A.N. Analysis and interpretation, A.S.D., S.N.R., T.H.v.R., M.A.P., S.P.M., and E.A.N. Drafting the manuscript for important intellectual content, M.M., A.S.D., and E.A.N. Review and editing of manuscript, M.M., A.S.D., P.A.J., S.N.R., T.H.v.R., S.P.M., and E.A.N.

Correspondence and requests for reprints should be addressed to Edward A. Nardell, M.D., Brigham and Women's Hospital, Division of Global Health Equity, 641 Huntington Avenue, 3A-03, Boston, MA 02115. E-mail: enardell@partners.org

At a Glance Commentary

Scientific Knowledge on the

Subject: The efficacy of upper room air disinfection is no longer in doubt, but so far there has been only one other hospital-based field study involving humans as the source of transmission and infection (of guinea pigs) as the endpoint. For 60 years, the application of upper room ultraviolet (UV) germicidal irradiation has been hampered by inadequate application guidelines, primarily based on fixture input wattage, not UV output. This is the first hospital-based study to have characterized conditions sufficiently well to provide a basis for international application guidelines.

What This Study Adds to the

Field: Beyond demonstrating an approximately 80% reduction in transmission, this is the first field study to attempt to completely define the conditions responsible. Moreover, it highlights the need for basing UV fixture number and location on fixture UV output, not electrical input, as has been done in the past. The proposed application guidelines are based on the entire room volume, either total fixture output per cubic meter volume or, using a recently characterized computer-assisted design program, the average UV irradiance (fluence rate) for the entire room volume. These application guidelines should provide a firm scientific basis for a critically important technology that is often poorly applied, especially in high-burden settings in which institutional airborne tuberculosis transmission is a key factor driving the global tuberculosis epidemic.

Ultraviolet (UV) germicidal irradiation (UVGI) has long been a standard method of water disinfection, but although rigorously studied, UVGI air disinfection has been less well accepted and is poorly defined in terms of evidence-based international application guidelines (1). The most important global application of upper room UVGI is to prevent the spread of *Mycobacterium tuberculosis* (*Mtb*) in health care and other congregate spaces, especially in high-burden, resource-

limited settings (2). The high volume of mechanical ventilation (6–12 air changes per hour [ACH]) recommended for the prevention of airborne infection is often not feasible in these settings. Facilities in suitable climates often depend on natural ventilation, which can be highly effective in well-designed buildings under optimal outside conditions, but can also be inadequate when conditions are suboptimal, and at night when windows may be closed for thermal comfort, pest control, or security (3). In cold climates natural ventilation is often not a practical option, but even in hot climates, as air conditioning becomes more widely used for thermal comfort, windows are usually closed. In these and other settings, upper room UVGI, often combined with natural or mechanical ventilation, may be the most cost-effective method for providing effective air disinfection.

Wall- or ceiling-mounted UVGI fixtures are designed to produce an intensive air disinfecting zone in the upper room, above people's heads, while limiting irradiation in the lower, occupied room to prevent eye and skin irritation of room occupants (4–6). Air mixing between the upper and lower room, commonly ensured by low-velocity ceiling fans, results in effective air disinfection in the occupied breathing zone (7–9). Efficacy of upper room UVGI depends on three principal factors: (1) the average UVGI fluence rate (irradiance from multiple sources) produced in the upper room and its distribution, (2) the rate of vertical air mixing, and (3) the UV susceptibility of the organism under ambient conditions (10–12). Using aerosolized surrogate test organisms in room-size test chambers, and microbiologic air sampling, various researchers have reported upper room UVGI air disinfection equivalent to 10, 20, and even higher ACH (7, 12–15). In contrast to the upper room application, except in very small rooms, most UVGI-based room air cleaners (air moving devices) are greatly limited by their clean air delivery rate, short-circuiting of processed air, and resulting low equivalent ACH (16).

Despite extensive laboratory evidence of efficacy over many years, the paucity of convincing field trials in clinically relevant settings has been a major barrier to full acceptance, technology development, and wider implementation of upper room UVGI (17). Here we report the results of a controlled field trial of the effectiveness of upper room UVGI with air mixing to reduce transmission of *Mtb* from patients

with multidrug-resistant (MDR) or extensively drug-resistant tuberculosis (TB) in a provincial referral hospital in South Africa. Because mechanical microbiologic air sampling is not feasible for naturally generated *Mtb*, we used highly susceptible guinea pigs as biologic air samplers, using infection (detected by the tuberculin skin test [TST]) as the most clinically relevant endpoint (18). We also report on the application of a recently validated computer-assisted design (CAD) program (Visual-UV; Acuity Brands, Connors, GA) to better define critical UVGI parameters, such as average room germicidal UV fluence rates (19). Finally, based on the results of this trial, we propose two new dosing strategies using total UVGI fixture output for determining the germicidal irradiation required in designing highly effective UVGI room installations. Some of the results of these studies have been previously reported in the form of an oral abstract presentation (20).

In their classic 1958–1962 experiments, Riley and colleagues (21–24) quantified the airborne transmission of human-source *Mtb* using hundreds of highly susceptible sentinel guinea pigs exposed to the air exhausted from an experimental six-bed TB ward in a Baltimore hospital. The investigators had also intended to test the efficacy of upper room UVGI, as evident in the 1959 paper describing the experimental ward where a UVGI wall fixture is illustrated in a patient room (21). But, after 4 years of experiments, the hospital reclaimed the ward for other purposes, and upper room UVGI was never tested. In 1996, however, Riley's longtime research collaborator, the late Solbert Permutt, suggested a novel design for air disinfection experiments, using two guinea pig chambers to control for variable patient infectiousness (25, S. Permutt, personal communication). His concept called for one guinea pig exposure chamber (intervention chamber) to receive exhaust air from the ward only every other day, the days when upper room UVGI was turned on in the ward; and the other exposure chamber (control chamber) to receive exhaust air from the same ward only on the alternate days, when upper room air disinfection was turned off. This experimental design ensured that patient infectiousness would be equivalent during the cumulative intervention and control periods. After months of exposure to ward air, any

differences in the TST reaction rates between the two guinea pig chambers would be a direct measure of the effectiveness of UVGI.

In the last decade two research groups have reestablished experimental TB hospital wards similar to Riley's for the purpose of studying TB transmission and control strategies, and have adopted Permutt's alternate-day experimental design (17). Thus far, upper room UVGI, room air ionizers, masks on patients, portable room air cleaning (filtration) machines, and inhaled antibiotics have been subjected to controlled testing in very different clinical settings in Peru and South Africa (17, 26). Escombe and coworkers (17) reported the effectiveness of upper room UV in a TB/HIV ward occupied by patients with mostly drug-susceptible TB in Lima, Peru. The present study tests the effectiveness of upper room UVGI with air mixing in an MDR-TB referral hospital in South Africa as a basis for proposed new dosing guidelines.

Methods

The Airborne Infections Research Facility

This study was performed at the airborne infections research (AIR) facility in eMahlaheni, South Africa. Like Riley's facility, the AIR facility was designed to expose hundreds of susceptible sentinel guinea pigs to airborne TB (infectious droplet nuclei) generated by patients with active, culture-proven, mostly sputum smear-positive, cavitary, pulmonary TB. The facility is physically part of the Mpumalanga Provincial MDR-TB Referral Hospital, and the patients recruited for this study were among those newly admitted with highly drug-resistant TB and just started on standardized South African MDR-TB treatment. The facility consists of a six-bed inpatient MDR-TB ward connected by an airtight ventilation system to two identical guinea pig exposure chambers (Figure 1). The study methods (human and animal protocols) were identical to our previously published study of the effectiveness of surgical masks on patients, but instead of masks on patients, upper room UVGI was turned on in the three patient rooms and corridor every other day (27). Human subjects in this study served only to generate infectious aerosols while on the ward. They received




Figure 1. Layout of the airborne infections research facility showing three two-bed patient rooms, corridor, and patient day room.

exactly the same care and treatment as on the main MDR wards. Subject inclusion and exclusion criteria, recruitment, consent, and TB treatment were the same as in the published surgical mask study (23). This study was approved by the human and animal ethics committees of all participating organizations.

Selecting the UVGI Fixtures to be Tested

The goals of this research were to test the effectiveness of upper room UVGI air disinfection with air mixing in a real hospital setting, under defined conditions, using the best available UVGI fixtures, but not to test any one manufacturer's product. Based on our published test chamber experiments and fixture testing, technical specifications for wall fixtures to be used in this study were developed and candidate fixtures solicited in the United States and South Africa (see the online supplement). Unless previously characterized at the Harvard School of Public Health, samples of stock or custom manufactured fixtures claiming to meet these specifications were tested for compliance.

Among those submitted for consideration, only two fixtures approximated our specifications. Both were made in the United States. Each manufacturer donated six wall fixtures for the study, one each for the three patient rooms, the hallway, common room, and one of each

to be kept in reserve should a fixture fail. Spare lamps for each fixture were also on hand. The fixtures were mounted 2.1 m from the ground, on opposite walls, but staggered to produce as uniform a UVGI distribution as possible from two sources, and the longest (estimated) average UV ray length possible in the room (Figures 2A and 3).

The commonly available ceiling fans used in the three patient rooms and the corridor (Figure 2C) had three blades 0.46-m length, and operated at all times at 100 rpm in the upward direction. Air was also mixed by the heating, ventilation, and air conditioning system, which ran at six ACH (outside air) during this 7-month exposure experiment. Details on ventilation and average humidity are discussed in the online supplement.

Results

The Experiments

When an initial 4-month exposure study resulted in too few guinea pig infections in the control chamber to meet our power calculation requirements, a nearly identical second 3-month experiment was subsequently conducted with fresh animals and additional human subjects. The only difference between the two experiments was a change in the location of the exhaust ducts from the patient rooms. When the first UV study showed only nine guinea pig




Figure 2. (A) Ultraviolet germicidal irradiation wall fixture, (B) room ventilation arrangement, and (C) ceiling paddle fan model in use during experiments. Note that the photograph in A was taken wearing ultraviolet protective goggles because even brief direct exposure at close range to upper room ultraviolet germicidal irradiation lamps can cause corneal inflammation. The arrows in B indicate air movement.

TST conversions, all under control conditions (Table 1), we questioned whether the upper room location of the exhaust ducts in the patient rooms might be contributing to this preliminary 100% efficacy estimate by selectively sampling irradiated air. Exhaust ports were relocated to the breathing zone positions indicated in Figure 2B. However, as predicted by our engineers, subsequent tracer gas studies and air flow modeling indicated that the ceiling fans produced well-mixed conditions, that is, exhaust air was not disproportionately exhausted from the irradiated zone (28). There was no scientific rationale not to combine the results of the two experiments in the

analysis, as presented in the Kaplan-Meier plot (Figure 4) showing the proportion getting infected, at least once, as a function of time, accommodating the killed animals as censored. This does not depict the multiple infections of a single animal.

To incorporate the possibility of multiple hits we use a Poisson model and estimate the monthly rate of infection using maximum likelihood. Even though we cannot accurately count the number of infections, we can count the numbers that escape infection each month. We calculate the probability of not getting infected as a function of the rate of infection to provide the likelihood equations. Using this method, we estimate that over the

3 months for the first study, there were a total of zero observed and zero estimated infections for the intervention group and a total of nine observed and 10.61 estimated for the control group. For the second study, over the 4 months, there were a total of 15 infections observed and 16.41 estimated for the intervention group, and 49 observed and 68.59 estimated for the control group. The Poisson correction method was similar to that routinely applied in mechanical air sampling (29). Uncorrected, an estimated 74% protection was calculated, whereas corrected for multiple hits, the estimated protection increased to approximately 80%.

Safety measurements were made at eye level with a sensitive 254-nm photometer (Gigahertz Optik, Newburyport, MA) before any patients entered the ward, and confirmed peak values of no more than $0.4 \mu\text{W}/\text{cm}^2$, values within local Medical Research Council guidelines and published recommendations, and highly unlikely to lead to eye or skin irritation among room occupants (30, 31). There were no eye or skin complaints registered by staff or patients during the study.

Discussion

Optimal application guidelines for upper room UVGI require evidence of safe and effective air disinfection in high-risk facilities, and careful characterization of the key parameters responsible. Our study demonstrates that two very well-characterized UVGI fixtures per room with ceiling fans provided an estimated 80% protection, statistically corrected for multiple hits. This is protection equivalent to adding approximately 24 ACH of ventilation. Escombe and colleagues (17) found 72% protection, uncorrected for multiple hits, almost identical to our uncorrected 74%, using very different fixtures and air mixing fans in a very different hospital setting in Peru. Moreover, the equivalent air changes added in this study are similar to what has been previously reported in several experimental room-scale studies, suggesting that upper room UVGI is a robust technology, not critically dependent on fine details as long as adequate average UVGI fluence rates are produced in the upper room and there is good vertical air mixing.




Figure 3. A computer-assisted design-generated illustration estimating the ultraviolet (UV) germicidal irradiation distribution in one of the patient rooms in the airborne infections research facility. The fixtures are represented by the blue ovoid structures on the near and far upper walls. The upper tricolor distribution represents three levels of ultraviolet germicidal irradiation flux in the “kill zone,” whereas the lower “safety” distribution indicates peak UV fluence rates 1.7 m (5.5 ft) from the floor.

Table 1. Crude TST Conversion Rate for Animals under Control and Ultraviolet Intervention Conditions by Month of Exposure for the Two Sequential Experiments (Combined in the Analysis)

TST (>6 mm)	Experiment 1		Experiment 2	
	Intervention	Control	Intervention	Control
Month 1	0	1	4	17
Month 2	0	3	12	31
Month 3	0	5	0	1
Month 4	0	0	—	—
Total	0	9	16	49

Definition of abbreviation: TST = tuberculin skin test.

Implications for Designing Upper Room UVGI Air Mixing Systems

At present, the number, location, and performance characteristics of UV fixtures required to reduce TB transmission (or other airborne infections) in rooms are poorly defined. A single room study by Riley and coworkers (32) over 30 years ago had long been the basis for the widely used guideline of one 30-W (nominal electrical power) UV fixture for 18.6 m² (200 sq ft). However, neither the total UVGI output (efficiency) of the 17-W unluvered fixture, nor the air mixing in the unventilated test room (radiator but no fan), were defined. Based on the more recent room studies of Miller and colleagues (13), the National Institute for Occupational Safety and Health (NIOSH) has suggested two alternative dosing strategies: either six lamp watts (UV) per cubic meter irradiated zone, or 30–50 μW/cm² average UV irradiance in

the upper room (1). However, like the Riley guideline, the first NIOSH dosing strategy does not consider fixture efficiency, which can vary greatly, as detailed in the online supplement. Although the second NIOSH guideline is based on fixture germicidal UV output, there is no standard method for measuring average upper room UVGI fluence rates and no practical way for planning an installation to achieve the recommended average.

UVGI room irradiance (fluence rates). To predict average germicidal UV fluence rates anywhere in rooms, we adapted and validated a commercially available CAD lighting tool called Visual (Acuity Brands) for upper room UVGI design purposes (Visual-UV) (19). With full goniometric input data for the two fixture models used in this study, Visual-UV software calculated UV fluence rates for the irradiated AIR facility areas. The average fluence rate in the upper

irradiated room (above 2.1 m, 24% of total room volume) was 19.5 μW/cm². Rather than the average UV fluency rates for a single fixture-level horizontal plane, reported in Miller and colleagues' study (13), or for the entire upper irradiated zone, Rudnick and First (33) proposed average fluency rates for the entire room volume as a preferable dosing parameter. Their reasoning was that disinfecting larger room air volumes requires additional UVGI fluence rates, not accounted for by the guidelines based on either single plane or upper irradiated zone average fluence rates. Visual UV calculated an average fluency rate for the three AIR facility patient rooms and corridor as 5.88 μW/cm², or approximately 6 μW/cm².

Rudnick and First (33) also suggested that under well-mixed conditions, the UVGI fluence parameter determining germicidal UV efficacy is approximated by the total UV fixture output (W/m³) per room volume. They made two other assumptions: that fluence rates are distributed as evenly as possible in the upper room; and that wall fixtures are positioned for maximum average ray length (including premature impact of rays on ceilings caused by any upward angle above the horizontal) (33). Under well-mixed conditions, all airborne organisms have an equal chance of exposure in the upper room until they are exhausted from the room. UVGI ray length is important because photons, although diverging, remain fully germicidal until they are absorbed by a surface. From this perspective, wall-mounted fixtures generally have longer average ray lengths compared with fixtures designed to be mounted in the center of rooms. To calculate total UV fixture output per room volume used in this study, we directly measured total fixture UV output for both fixture models using the integrating sphere method (courtesy of Professor W. Leuschner, University of Pretoria). In each patient room containing two fixtures, one of each design, the total combined UVGI fixture output (fluence rate) was 0.71 W, and the total fixture output for the entire treated space (volume 171 m³) was 2.9 W. Therefore, the total fixture UVGI output applied was 17 mW/m³ room volume.

By comparison with our 17 mW/m³ total room dose, a recalculation of Miller and colleagues' room study (13) (using aerosolized *Mycobacterium parafortuitum*) based on estimates of total fixture output of the fixtures used (nominal 216 W) results in




Figure 4. Kaplan-Meier risk estimates of combined tuberculin skin test conversions (y-axis) of exposed guinea pigs in control and intervention chambers by month (x-axis) of exposure. $P < 0.0005$; combined hazard ratio, 4.9 (95% CI, 2.8–8.6). CI = confidence interval.

a total dose of 12.6 mW/m³. Although differences in methods (including test organism susceptibility) preclude direct comparison, the similarity of outcomes is striking. In the two studies, a total average fixture dose of 13–17 mW/m³ resulted in an estimated 16–24 Eq ACH. This agreement, while requiring confirmation, suggests that the total UV fixture dose per room volume may be more useful than older dosing guidelines. We do not know enough about the germicidal output of the fixtures used in Escombe and colleagues' hospital study (17) (the only other human to guinea pig *Mtb* transmission UVGI experiment) to make a similar estimate. With adequate mixing, higher doses than those used in the study reported here would likely have produced greater air disinfection, but also a potentially greater risk of occupant UVGI exposure. For that reason we suggest a target range of 15–20 mW/m³. Although 16–24 added Eq ACH is much higher (and less costly) than can be routinely accomplished by other means of air disinfection, further studies are needed to determine the upper practical limits of safe upper room UVGI air disinfection in occupied spaces.

Dosing strategy 1 (practical method, not requiring CAD). Based on this hospital-based study we suggest providing at least 15–20 mW/m³ total fixture wattage to each room. To calculate the number of fixtures needed, total germicidal UV output for each fixture model must be provided by the manufacturer, based on measurements in a qualified lighting laboratory using the integrating sphere method or full goniometry. Upper room fixtures should be positioned to keep the beam at least 2.1 m above the floor. Fixture should be located to fulfill two further goals: to produce as even an upper room distribution of irradiance as possible, and to achieve maximum estimated average ray length in the upper room. Sample calculations are found in the online supplement. A simple direct measurement method for estimating total UV fixture output for louvered fixtures has been submitted for publication by Dr. Steven Rudnick, Harvard School of Public Health.

Dosing strategy 2 (requiring CAD [Visual-UV]). Visual-UV can calculate the average UV fluency rate for the entire room. The advantage of this dosing method is that average ray length is accounted for by the room specifications required as input by the CAD program. Using dosing strategy

1 (discussed previously) as a first approximation, Visual-UV can be used by trial and error to verify the number, design, and optimal location of fixtures required to produce an average room fluency rate of at least 5–7 $\mu\text{W}/\text{cm}^2$.

Beyond the total fixture UV output measurement required for dosing strategy 1, use of dosing strategy 2 requires full goniometric data of each fixture model as input for the Visual-UV program. In our view, fixture manufacturers should provide full output data (both measurements) for the fixture models that they sell. Ideally, a few high-quality lighting laboratories around the world will be used to measure fixture output for manufacturers using standardized methods. Both the laboratory and the specific methods used should be identified with the output measurements for each fixture model.

Closely spaced louvers greatly reduce fixture efficiency, but have been necessary for rooms with low ceilings (below 2.7 m) to prevent occupant overexposure (31). However, the same fixture with the louvers removed delivers up to seven times the UV output. Fixtures with less restrictive louvers can be used in rooms with very high ceilings (over 2.7 m) if eye-level photometry is performed to ensure safety (31). Another approach where ceiling heights permit is to use the same wall fixtures without louvers above an “eggcrate” ceiling, which interferes little with airflow but intercepts stray or reflected UV ray that would otherwise reach the occupied lower room (34).

Air Mixing

Ceiling fan performance is characterized by the airflow rate generated, which is measured by a method prescribed by the U.S. Environmental Protection Agency (35). To normalize this airflow rate, it is divided by room volume, resulting value in h⁻¹, called the fan's air turnover rate. Although no actual airflow measurements were made for our study, the air turnover rate of the fans was calculated to be 57 h⁻¹ using a computational fluid dynamics method similar to that published by Zhu and coworkers (36).

The Miller and colleagues and Escombe and colleagues studies cited used different approaches to air mixing and also obtained good germicidal efficacy (13, 17, 37). Although room air stagnation needs to be avoided, recent studies have confirmed

earlier impressions that, within a wide range easily achieved with conventional low-velocity ceiling fans, neither the direction of airflow nor the exact air turnover rate between the upper and lower room seem to be critical application parameters (38).

Patient comfort under cool and warm conditions may also determine fan speed and direction. For rooms with very high ceilings, downward flow direction is more likely to avoid air stagnation in the lower room.

Limitations

Although sampling exhaust air from the ward accurately reflects the average infectiousness of well-mixed ward air, it may not reflect transient higher local concentrations before mixing occurs and the associated risk to those working in close proximity to patients. However, in this study, tracer gas studies and airflow modeling did reveal well-mixed conditions from the ceiling fans, making high local concentrations less likely. Although the engineering parameters described can easily be achieved with commercially available equipment, regular maintenance of upper room UVGI equipment is essential to ensure the predicted equivalent air changes (*see* online supplement).

Conclusions

This study confirms the high effectiveness of upper room UVGI with air mixing under realistic hospital conditions and defines parameters for its safe and effective application. It shows that commercially available upper room fixtures all generate useful germicidal irradiation, but vary greatly in efficiency. Because most dosing formulae have been based on nominal lamp wattage, or UV wattage, rather than total fixture output, rooms using inefficient fixtures may be greatly underdosed. Total fixture germicidal UV output must be known and incorporated into any dosing formula. For ceilings over 2.6 m, tightly louvered fixtures may not be needed and much more efficient fixtures can be used. Eggcrate UV is a promising, more efficient approach to upper room UVGI (34). With fixtures of any design, we recommend using either of two dosing strategies based on total fixture output: 15–20 mW/m³ total fixture UV wattage delivered per room volume (with fixtures arranged for

maximum ray length and upper room coverage), or 5–7 $\mu\text{W}/\text{cm}^2$ average UV fluence rate in the entire room calculated by a validated CAD program (Visual is available for UV dose calculations at no charge through Richard.Vincent@mountsinai.org). Either method requires that fixture

manufacturers supply users with detailed data on the UV output of their fixtures.

Author disclosures are available with the text of this article at www.atsjournals.org.

Acknowledgment: This article is dedicated to the memory of Drs. Melvin First, Phillip Brickner,

and Sidney Parsons, who contributed substantially to the application of germicidal ultraviolet air disinfection to prevent tuberculosis spread. The authors thank Kobus Venter and Willem Lubbe for their technical support; Atlantic Ultraviolet Corporation (Hauppauge, NY) and Lumalier, Inc. (Memphis, TN) for ultraviolet fixtures; and the South African patients who generously contributed their time to this study.

References

- National Institute for Occupational Safety and Health. Environmental control of tuberculosis: basic upper-room ultraviolet germicidal irradiation guidelines for healthcare settings. Atlanta, GA: National Institute for Occupational Safety and Health; 2009.
- Nardell E, Dharmadhikari A. Turning off the spigot: reducing drug-resistant tuberculosis transmission in resource-limited settings. *Int J Tuberc Lung Dis* 2010;14:1233–1243.
- World Health Organization. Natural ventilation for infection control in health care settings. Geneva, Switzerland: World Health Organization; 2009.
- Nardell E, Riley RL. A new ultraviolet germicidal irradiation (UVGI) fixture design for upper room air disinfection with low ceilings. Presented at the World Congress on Tuberculosis, November 16–19, 1992, Bethesda, MD.
- Rudnick SN. Predicting the ultraviolet radiation distribution in a room with multilouvered germicidal fixtures. *AIHAJ* 2001;62:434–445.
- Riley RL, Nardell EA. Clearing the air. The theory and application of ultraviolet air disinfection. *Am Rev Respir Dis* 1989;139:1286–1294.
- Riley RL, Permutt S. Room air disinfection by ultraviolet irradiation of upper air: air mixing and germicidal effectiveness. *Arch Environ Health* 1971;22:208–219.
- Riley RL, Permutt S, Kaufman JE. Convection, air mixing, and ultraviolet air disinfection in rooms. *Arch Environ Health* 1971;22:200–207.
- Riley RL, Permutt S, Kaufman JE. Room air disinfection by ultraviolet irradiation of upper air: further analysis of convective air exchange. *Arch Environ Health* 1971;23:35–39.
- First M, Nardell E, Chaisson W, Riley R. Guidelines for the application of upper-room ultraviolet germicidal irradiation for preventing transmission of airborne contagion. Part II: Design and operations guidance. *ASHRAE Transactions* 1999;105:877–887.
- First M, Nardell E, Chaisson W, Riley R. Guidelines for the application of upper-room ultraviolet germicidal irradiation for preventing transmission of airborne contagion. Part I: Basic principles. *ASHRAE Transactions* 1999;105:869–876.
- First M, Rudnick SN, Banahan KF, Vincent RL, Brickner PW. Fundamental factors affecting upper-room ultraviolet germicidal irradiation. Part I. Experimental. *J Occup Environ Hyg* 2007;4:321–331.
- Miller SLHM, Fennelly K, Martyn J, Macher J. Efficacy of ultraviolet irradiation in controlling the spread of tuberculosis. 2002 [accessed 2002 Oct 19]. Available from: <http://www.cdc.gov/niosh/reports/contract/pdfs/ultrairTB.pdf>
- Ko G, First MW, Burge HA. The characterization of upper-room ultraviolet germicidal irradiation in inactivating airborne microorganisms. *Environ Health Perspect* 2002;110:95–101.
- McDevitt JJ, Milton DK, Rudnick SN, First MW. Inactivation of poxviruses by upper-room UVC light in a simulated hospital room environment. *PLoS One* 2008;3:e3186.
- Nardell EA. Fans, filters, or rays? Pros and cons of the current environmental tuberculosis control technologies. *Infect Control Hosp Epidemiol* 1993;14:681–685.
- Escombe AR, Moore DA, Gilman RH, Navincopa M, Ticona E, Mitchell B, Noakes C, Martínez C, Sheen P, Ramirez R, et al. Upper-room ultraviolet light and negative air ionization to prevent tuberculosis transmission. *PLoS Med* 2009;6:e43.
- Nardell EA. Air sampling for tuberculosis: homage to the lowly guinea pig. *Chest* 1999;116:1143–1145.
- Rudnick SN, First MW, Sears T, Vincent RL, Brickner PW, Ngai P, Zhang J, Levin RE, Chin K, Rahn RO, et al. Spatial distribution of fluence rate from upper room ultraviolet germicidal irradiation: experimental validation of a computer-aided design tool. *HVAC&R Research* 2012;18:774–794.
- Mphahlele M. Highly effective upper room ultraviolet air disinfection on a MDR-TB ward in Sub-Saharan Africa [abstract]. Presented at the International Union Against Tuberculosis and Lung Disease Annual Scientific Meeting. December 3–6, 2009, Cancun, Mexico.
- Riley RL, Wells WF, Mills CC, Nyka W, McLean RL. Air hygiene in tuberculosis: quantitative studies of infectivity and control in a pilot ward. *Am Rev Tuberc* 1957;75:420–431.
- Riley RL, Mills CC, O'Grady F, Sultan LU, Wittstadt F, Shivpuri DN. Infectiousness of air from a tuberculosis ward. Ultraviolet irradiation of infected air: comparative infectiousness of different patients. *Am Rev Respir Dis* 1962;85:511–525.
- Riley RL. What nobody needs to know about airborne infection. *Am J Respir Crit Care Med* 2001;163:7–8.
- Riley RL, Mills CC, Nyka W, Weinstock N, Storey PB, Sultan LU, Riley MC, Wells WF. Aerial dissemination of pulmonary tuberculosis. A two-year study of contagion in a tuberculosis ward. 1959. *Am J Epidemiol* 1995;142:3–14.
- van Geuns HA. Tuberculosis control in the eradication phase in The Netherlands. *Bull Int Union Tuberc Lung Dis* 1989;64:31–32.
- Dharmadhikari AS, Basaraba RJ, Van Der Walt ML, Weyer K, Mphahlele M, Venter K, Jensen PA, First MW, Parsons S, McMurray DN, et al. Natural infection of guinea pigs exposed to patients with highly drug-resistant tuberculosis. *Tuberculosis (Edinb)* 2011;91:329–338.
- Dharmadhikari AS, Mphahlele M, Stoltz A, Venter K, Mathebula R, Masotla T, Lubbe W, Pagano M, First M, Jensen PA, et al. Surgical face masks worn by patients with multidrug-resistant tuberculosis: impact on infectivity of air on a hospital ward. *Am J Respir Crit Care Med* 2012;185:1104–1109.
- van Reenen T. Assessment of room air mixing due to low velocity ceiling fans in the AIR facility [internal report]. Pretoria, South Africa: Council for Scientific and Industrial Research; 2013.
- Macher JM. Positive-hole correction of multiple-jet impactors for collecting viable microorganisms. *Am Ind Hyg Assoc J* 1989;50:561–568.
- Coker I, Nardell E, Fourie B, Brickner P, Parsons S, Bhagwandin N, Onyebujoh P, editors. Guidelines for the utilisation of ultraviolet germicidal irradiation (UVGI) technology in controlling transmission of tuberculosis in health care facilities in South Africa. Pretoria: Medical Research Council; 2000.
- Nardell EA, Bucher SJ, Brickner PW, Wang C, Vincent RL, Becan-McBride K, James MA, Michael M, Wright JD. Safety of upper-room ultraviolet germicidal air disinfection for room occupants: results from the Tuberculosis Ultraviolet Shelter Study. *Public Health Rep* 2008;123:52–60.
- Riley RL, Knight M, Middlebrook G. Ultraviolet susceptibility of BCG and virulent tubercle bacilli. *Am Rev Respir Dis* 1976;113:413–418.
- Rudnick SN, First MW. Fundamental factors affecting upper-room ultraviolet germicidal irradiation. Part II. Predicting effectiveness. *J Occup Environ Hyg* 2007;4:352–362.

34. Linnes JC, Rudnick SN, Hunt GM, McDevitt JJ, Nardell EA. Eggcrate UV: a whole ceiling upper-room ultraviolet germicidal irradiation system for air disinfection in occupied rooms. *Indoor Air* 2014;24:116–124.
35. EPA. Energy star laboratory guidance manual: building a testing facility and performing the solid state test method for energy star qualification of ceiling fans. Version 1.2. Washington, DC: Environmental Protection Agency; 2011.
36. Zhu S, Srebric J, Rudnick SN, Vincent RL, Nardell EA. Numerical modeling of indoor environment with a ceiling fan and an upper-room ultraviolet germicidal irradiation system. *Build Environ* 2014;72:116–124.
37. Peng X, Peccia J, Fabian P, Martyny J, Fennelly K, Hernandez M, Miller S. Efficacy of ultraviolet germicidal irradiation of upper-room air in inactivating airborne bacterial spores and mycobacteria in full-scale studies. *Atmos Environ* 2003;37:405–419.
38. Rudnick SN, McDevitt JJ, Hunt GM, Stawnychya MT, Brickner PW. Influence of ceiling fan's speed and direction on efficacy of upper-room ultraviolet germicidal irradiation—Part I. Experimental, building and environment 2014. *Build Environ* [online ahead of print] 12 Apr 2014; DOI: 10.1016/j.buildenv.2014.03.025.

Online Supplement:

Institutional Tuberculosis Transmission:

A Controlled Trial of Upper Room Ultraviolet Air Disinfection

Technical Specifications and Dosing Guideline Application

1: Air Facility ward conditions, staffing, ventilation, humidity, and infection control.

Ventilation: The Airborne Infectious Research (AIR) Facility where this study was conducted in Mumpumalanga, South Africa, functions as a *separation* ward for multidrug resistant tuberculosis (MDR-TB) patients, not as a true *isolation* ward, in the sense of isolating individual patients. According to 2011 national policies and procedures for managing MDR-TB in South Africa, separation, not *individual* isolation, of patients with MDR-TB is the norm. The policy states that the following classes of patients should be separated: newly admitted MDR-TB patients (vs. patients after 2 weeks therapy), known extensively resistant tuberculosis (XDR-TB) patients, children, and those critically ill. Natural ventilation is the norm, but if considered inadequate, window exhaust fans or mechanical ventilation is recommended to achieve 6 air changes per hour (ACH). The AIR Facility receives 6 mechanical ACH (100% outside air), and is the only mechanically ventilated ward in the hospital. The Mpumalanga MDR Tuberculosis Treatment Center has 4 other MDR wards in naturally ventilated buildings. Because Witbank (eMalalani) is at high altitude (5,354 ft.), doors and windows are often closed at night as the temperature drops, and often all day in winter. In addition, since these are single-story structures, security concerns prompt patients to close windows and doors at night. We

estimate that in the naturally ventilated wards, although not measured, air exchanges ranges from very good on some days when there is a breeze and it is warm enough to keep windows open, to very little (< 2 ACH) on still days and at night or on cold days when windows and doors are closed. Ventilation at 6 ACH outside air in the AIR facility ward is assured, and generally much better than that existing in the rest of the hospital.

Humidity. High relative humidity (above 70%) is believed to reduce the efficacy of upper room germicidal UV air disinfection, although this concern is based primarily on laboratory experiments, not clinical trials.(1) Escombe's reported overall efficacy of 72% for a similar controlled trial of UVGI efficacy in Lima, Peru during which humidity averaged 70-90% for nearly 2 years on the mechanically ventilated ward with no cooling or dehumidification.(2) Although average outside RH in eMahalani ranged from 57 to 76% during the summer months of the study reported here, the ward was air conditioned and cooled, and the ambient humidity in the three patient rooms continuously recorded by the automated building management system rarely exceeded 50%. In a previous unpublished study we were unable to maintain humidity on the ward at greater than 70%. Therefore, the study reported in the main published article does not contribute to our understanding of the use of upper room UVGI at high humidity.

Occupancy, hospital conditions, and infection control practices: Subjects are recruited for transfer to the AIR facility from the main hospital soon after admission. They generally stay on the AIR facility only 2 weeks out of their average 6-month hospital stay. The 4 main MDR wards have 31 closely spaced beds each, for a total of 124 beds - half male

and half female. There are also 2 XDR wards with 13 beds (8 female, 5 male). These wards are staffed by 6 professional nurses (4 day, 2 night), 1 enrolled nurse, and 6 assistant nurses (4 day, 2 night). The AIR facility, in contrast, has 3, 2-bed rooms and a common room, providing much more personal space and considerably more privacy than on the main MDR wards. This AIR ward is staffed by one RN during the day and, for safety, an RN and practical nurse at night. There is an enclosed and separately ventilated nurse's station on the AIR facility ward that allows *supervision of the 3 rooms, corridor, and common room*. As a result of the more comfortable accommodations and much greater nursing and medical supervision, subjects are generally happy to transfer to the AIR facility, and reluctant to leave when their 2 weeks are up. In both the main MDR hospital and in the AIR facility patients are instructed on cough hygiene and all workers are instructed to use N-95 respirators when in the ward. As in many high burden settings, compliance with respirator use is often poor for a variety of reasons. Many health care workers understand that they were likely already TB-infected and fail to appreciate the risk of reinfection. In contrast, animal handlers are required to use half-face elastomeric respirators when working in the animal quarters. Based on passive surveillance, we are not aware of any TB cases among our nurses or animal workers over the 10 years that the AIR Facility has been operating.

2: UVGI Fixture specifications and variable output

As noted in the main paper, the goal of this research were to test the efficacy of upper room UVGI air disinfection in a real hospital setting, under defined conditions, using the best available UVGI fixtures, but not to test any one manufacturer's product. Based on

our published test chamber experiments and fixture testing, technical specifications for wall fixtures to be used in this study were developed and candidate fixtures solicited in the USA and South Africa.(3) The key performance specifications that guided selection of the UVGI fixtures used in this study were:

1. *Upper room power* - Not less than $250 \mu\text{W}/\text{cm}^2$, measured with a UV-C meter one meter away from the face/opening of the fixture, on the horizontal centerline of the UVGI beam.
2. *Lower room safety* – No more than $0.4 \mu\text{W}/\text{cm}^2$ at 2.0 m (6.5 ft) above the floor anywhere in the room, measured with a sensitive UV-C meter. UV-C fluence rates no higher than $0.4 \mu\text{W}/\text{cm}^2$ at eye level in the lower room is consistent with published South African Guidelines and current UV safety publications.(4, 5)

Total UV Fixture Output and Efficiency: The two selected fixtures were: A) a custom made 110W wall fixture (Lumalier, Inc., Memphis, TN); and B) a standard 25 W Hygeaire wall fixture (Atlantic Ultraviolet Corp., Hauppauge, NY). While both louvered fixture models selected to meet defined performance specifications provided safe and highly effective air disinfection, this study confirmed earlier observations that fixture efficiency varied greatly between models.(3) Most currently available wall and suspended fixtures use closely-spaced louver systems to absorb UV radiation that would otherwise reach the occupied space, directly or by reflection from the ceiling. As a result of major design differences, the efficiency of the two selected fixture models differed greatly. (Table S1) Fixture A utilized 2-55 W compact UVGI lamps but produced only 0.22 W total radiant UV flux (efficiency 0.6%). Fixture B utilized 1-25.6 W linear UVGI lamp but produced 0.49 W total

radiant UV flux (efficiency 5.7%). With louvers removed fixture B was still more than twice as efficient as fixture A, because of a more effective parabolic reflector behind an optically more desirable linear lamp compared to the folded compact lamp in fixture A. Although fixture output differences had been reported previously, the full implications of efficiency differences for dosing strategies had not been fully appreciated.(3) Clearly, fewer fixtures and less electricity will be required for room installations using more efficient fixtures. Moreover, conventional dosing guidelines for the number of UV fixtures per room have commonly been based on nominal electrical or UV power, not total fixture UV output, resulting in radically different numbers of fixture recommendations based on different dosing formulas. Using Riley's 30 nominal W/200 /ft² area guideline, for example, only one 110 W model A fixture would be recommended for the entire AIR facility (see full paper), but it would produce only 0.2 W total output, whereas five 25 W model B fixtures would be recommended for the same application, producing approximately 2.5 W, a greater than ten-fold difference.(6) With the NIOSH guideline of 6 total UV W/m³ of upper room volume, approximately 7 model A fixtures would be specified for the AIR facility, but produce only 1.5 W total output (half that used in this study), but 29 of the more efficient B model fixtures would be specified, producing 14 W, nearly 5 times the output actually required.[7] Our proposed guidelines, based on total fixture UV output per room volume, incorporates fixture efficiency and eliminates these dosing aberrations.

3. Examples of applying the recommended UVGI dosing strategies in relatively small and large rooms:

The 15-20 mW/m³ dosing strategy was derived from the AIR Facility experiment, a space with a series of relatively small 2 bed rooms (40.5 m³ each) and a somewhat larger

corridor (50.6 m³). In much larger rooms, due to the benefits of longer UVGI ray length, and depending on the reflectance of surfaces, this formula will result in somewhat higher average UVGI fluence rates, which should be beneficial in large rooms, especially those with high ceilings where reflectance into the lower room is not a problem. The second dosing strategy, using Visual-UV, gives more precise guidance, taking into account actual room shape, volume, as well as fixture location, output distribution, and estimated reflectance. Below are two examples of the application of both proposed dosing strategies.

a) *Small room - simple dosing method requiring only total UV fixture output:*

A 54 m³ room (3 m x 6 m x 3 m high) would require 15-20 mW/m³, or 810-1080 mW total germicidal UV output wattage. Fixture B generates approximately 500 mW so two fixtures would achieve the desired dose. In a rectangular room they would be installed on opposite short (3 m walls) for maximum ray length, and staggered (not exactly opposite each other) for the most even UVGI distribution, as illustrated in Fig S1. Based on this calculation, two fixtures could be installed at approximately 2.1 m above the floor. Before use the room would be spot checked (part of commissioning) for locations in the occupied space where eye levels exceed 0.4 mW/m³, the 4-hour continuous stare-time exposure limit.[4] Where prolonged stare time is unlikely, higher local measurements can be tolerated, well within the ACGIH TLV. [5]

Visual-UV CAD method: For greater precision (incorporating ray length, room configuration, fixture locations, and lower room fluence rate estimates), Visual-UV can be used, but requires full gonioradiometric data for the fixtures being used. In this simple, rectangular room, the two staggered fixtures (model B) at 2.1 m above the floor on the

opposite short walls (longer ray length) result in an average whole room UVGI fluence rate of $6.97 \mu\text{W}/\text{cm}^2$, within the proposed 5-7 $\mu\text{W}/\text{cm}^2$ target range. If placed on the opposite long walls (shorter ray length) the predicted average fluence rate is $5.60 \mu\text{W}/\text{cm}^2$, about 24% less. In this small room, average UVGI fluence rate is higher if both fixtures are centered on opposite walls due to UVGI absorptive loss by impacting the closest lateral wall, but more “hot spots” are produced, and optimal air disinfection becomes more dependent on good air mixing.

b) *Large room:* A large room of 150m^3 (5 x 10 x 3 m) would require 15-20 mW/m^3 , or a total of 2250-3000 mW. This would require 5 model B louvered wall fixtures (producing 500 mW each), evenly spaced and staggered on opposing 5 m walls to produce as even a distribution as possible. If the room specifications and full gonioradiometric data for the fixture are used with the Visual-UV CAD program, an average UV fluence rate for the entire room of $8.3 \mu\text{W}/\text{cm}^2$ is predicted due to longer average ray length. Although higher than the 5-7 $\mu\text{W}/\text{cm}^2$ dose used in the AIR Facility experiment, reducing the number of fixtures from 5 to 4 results in predicted average UVGI fluence rates within the target range. Either 4 or 5 fixtures would produce high rates of air disinfection, the decision dictated by considerations of airborne infection risk, fixture installation and operating costs, and UV fluence rates at eye level in the lower room.

Higher ceilings: With higher ceilings (over 3 m), it is possible to safely use fixtures with less restrictive louvers (or no louvers at all above an “eggcrate” ceiling), greatly increasing total fixture output and reducing the number of fixtures required.[8] This is because unlouvered fixtures can have many times the total UV output of louvered fixtures.[3] For

example, the same 5 m x 10 m room with a 4 m high ceiling (volume 200 m³) would require seven 500 mW fixtures (3 – 4 total W) based on the 15-20 mW/m³ formula, but since the same unlouvered fixture has much greater total UV output (4.2 W), just one wall fixture could be safely used above an eggcrate ceiling. The eggcrate ceiling helps prevent reflected UV rays from entering the occupied level of the room, but spot checks with a sensitive UV meter are still needed.(7)

Maintaining UVGI-air mixing systems: The above guidelines are intended to allow engineers to produce highly effective air disinfection systems. However, it is common to find even well designed UVGI fixtures poorly maintained in hospitals and clinics, with lamps coated with dust, fixtures full of dead bugs, and low-velocity ceiling fans turned off, or not present at all. Effectiveness of these systems is dependent on good maintenance as well as good design. Maintenance is not difficult, but must be regularly done by a trained technician. Fixtures should be turned off (to avoid eye injury) and lamps carefully cleaned with 70% alcohol every 1 to 3 months depending on the dustiness of the environment. Lamps should be replaced when irradiance (measured by a UVC photometer at the same exact spot for each fixture) falls below 67% of the initial values measured after a 100 hour “burn in” (8)

Figures and Tables:




Figure S1: Suggested layout of two fixtures in an oblong room to achieve both optimal distribution and maximum estimated ray length.

	Total Electrical Input	UV Generated	UV Output from Fixture	UV Efficiency (UV Output/UV generated)	Total Efficiency (UV Output/Total Electrical Input)
Fixture A	110 W	36.7 W	0.22 W	0.6 %	0.2 %
Fixture B	25.6 W	8.57 W	0.49 W	5.7 %	1.9 %

Table S1: Fixture efficiency based on testing at the U. Pretoria, Prof. Wilhelm Leushner's laboratory.

References:

1. Ko G, First MW, Burge HA. Influence of relative humidity on particle size and UV sensitivity of *Serratia marcescens* and *Mycobacterium bovis* BCG aerosols. *Tuber Lung Dis* 2000; 80: 217-228.
2. Escombe AR, Moore DA, Gilman RH, Navincopa M, Ticona E, Mitchell B, Noakes C, Martinez C, Sheen P, Ramirez R, Quino W, Gonzalez A, Friedland JS, Evans CA. Upper-room ultraviolet light and negative air ionization to prevent tuberculosis transmission. *PLoS medicine* 2009; 6: e43.
3. Dumyahn T, First M. Characterization of ultraviolet upper room air disinfection devices. *Am Indust Hyg Assoc J* 1999; 60: 219-227.
4. Coker I, Nardell E, Fourie B, Brickner P, Parsons S, Bhagwandin N, Onyebujoh P, editors. Guidelines for the utilisation of ultraviolet germicidal irradiation (UVGI) technology in controlling transmission of tuberculosis in health care facilities in South Africa. Pretoria: Medical Research Council; 2000.
5. Nardell EA, Bucher SJ, Brickner PW, Wang C, Vincent RL, Becan-McBride K, James MA, Michael M, Wright JD. Safety of upper-room ultraviolet germicidal air disinfection for room occupants: results from the Tuberculosis Ultraviolet Shelter Study. *Public Health Rep* 2008; 123: 52-60.
6. Riley R, Knight M, Middlebrook G. Ultraviolet susceptibility of BCG and virulent tubercle bacilli. *Am Rev Resp Dis* 1976; 113: 413-418.

7. Linnes JC, Rudnick SN, Hunt GM, McDevitt JJ, Nardell EA. Eggcrate UV: a whole ceiling upper-room ultraviolet germicidal irradiation system for air disinfection in occupied rooms. *Indoor air* 2014; 24: 116-124.
8. First M, Nardell E, Chaisson W, Riley R. Guidelines for the application of upper-room ultraviolet germicidal irradiation for preventing transmission of airborne contagion - Part II: Design and operations guidance. *ASHRAE Transactions* 1999; 105: 877-887.